

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product
Produit

CONDUIT SYSTEMS BURIED UNDERGROUND FOR CABLE MANAGEMENT

Name and address of the applicant
Nom et adresse du demandeur

TUBOS PERFILADOS, S.A.
CR CASTELLÓN KM 15,5 - PI LA NORIA
50730 EL BURGO DE EBRO (Zaragoza - SPAIN)

Name and address of the manufacturer
Nom et adresse du fabricant

TUBOS PERFILADOS, S.A.
CR CASTELLÓN KM. 15,500 - PI LA NORIA
50730 EL BURGO DE EBRO (Zaragoza - SPAIN)

Name and address of the factory
Nom et adresse de l'usine

SAME AS ABOVE

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

Additional Information on page 2

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

See Annex.

Trademark (if any)
Marque de fabrique (si elle existe)

TUPERSA

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

ULTRATP-I BARRAS; ULTRATP-I ROLLOS

Model / Type Ref.
Ref. De type

Additional information (if necessary may also be reported on page 2)
Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2^{ème} page

Additional Information on page 2

A sample of the product was tested and found to be in conformity with
Un échantillon de ce produit a été essayé et a été considéré conforme à la

IEC 61386-1:2008
IEC 61386-24:2004

As shown in the Test Report Ref. No. which forms part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

PLA-0723-1, PLA-0722-1

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification

ASOCIACIÓN ESPAÑOLA DE NORMALIZACIÓN Y CERTIFICACIÓN (AENOR)
CI Génova, 6
ES-28004 MADRID (SPAIN)

AENOR Asociación Española de Normalización y Certificación

Date: 2014-05-22

Signature: Avelino BRITO
Chief Executive Officer

ANNEX TO CB CERTIFICATE N° ES14459

CERTIFIED REFERENCES AND THEIR PRINCIPAL CHARACTERISTICS

PRODUCT: CONDUIT SYSTEMS BURIED UNDERGROUND FOR CABLE MANAGEMENT

Trade mark	Type Ref.	Type of conduit	Nominal diameter	Minimum inside diameter	Classification codes	Colour	Accessories	Additional information
TUPERSA	ULTRATP-I Barras	non metallic	90-110-125-160-200-250 mm.	74-90-102-135-169-212 mm.	450 N; Normal; Rigid; IP44 (1)	yellow, red, orange, green, violet, blue.	Sleeves : 90-110-125-160-200-250	Polyethylene
TUPERSA	ULTRATP-I Rollos	non metallic	40-50-63-75-90-110-125-160-200 mm.	30-37-48-58-74-90-102-135-169 mm.	450 N; Normal; Pliable; IP44 (2)	yellow, red, orange, green, violet, blue.	Sleeves: 40-50-63-75-90-110-125-160-200	Polyethylene

(1) Resistance to compression: Type 450 N.

Resistance to impact: Normal.

Resistance to bending: Rigid.

External influences: IP44

Resistance to flame propagation: Flame propagation

(2) Resistance to compression: Type 450 N.

Resistance to impact: Normal.

Resistance to bending: Pliable.

External influences: IP44

Resistance to flame propagation: Flame propagation