

AENOR

AENOR Product Certificate Conduit systems for cable management



030/002320

AENOR certifies that the organization

TUBOS PERFILADOS, S.A.

registered office CR CASTELLÓN KM 15,5 - PI LA NORIA 50730 EL BURGO DE EBRO (Zaragoza - España)

supplies Conduit systems buried underground for cable management

in compliance with UNE-EN 61386-1:2008 (EN 61386-1:2008; IEC 61386-1:2008)
UNE-EN 61386-1:2008 ERRATUM:2010
UNE-EN 61386-24:2011 (EN 61386-24:2010; IEC 61386-24:2004)

References Specified in Annex to the Certificate

Production site CL MAR MEDITERRANEO, 63 - PI SON BUGADELLES 07180 SANTA PONÇA (CALVIA) (Islas Baleares - España)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 030.12.

This certificate supersedes 030/002320, dated 2015-12-23

First issued on 2013-02-21
Modified on 2018-01-11
Validity date 2023-02-21

Rafael GARCÍA MEIRO
Chief Executive Officer

Original Electronic Certificate

AENOR

AENOR Product Certificate Conduit systems for cable management

030/002320

Annex to Certificate

Trade mark: TUPERSA

| Type Ref. | Type of conduit | Nominal diameter | Minimum inside diameter | Classification codes | Colour | Accessories | Additional information |
|------------------|-----------------|-----------------------------------|----------------------------------|----------------------|--|-------------------------------|------------------------|
| ULTRATP-I BARRAS | Non metallic | 90-110-125-160-200-250 mm | 74-90-102-135-169-212 mm | (1) | Red; Yellow; Green; Orange; Violet; Blue | Sleeves; Ref. TUPERSA ; black | Polyethylene |
| ULTRATP-I ROLLOS | Non metallic | 40-50-63-75-90-110-125-160-200 mm | 30-37-47-58-74-90-102-135-169 mm | (2) | Red; Yellow; Green; Orange; Violet; Blue | Sleeves , Ref. TUPERSA, black | Polyethylene |

- (1) Resistance to compression. Type 450 N.
Resistance to impact: Normal.
Resistance to bending: Rigid.
External influences: IP44
Resistance to flame propagation: Flame propagation
- (2) Resistance to compression. Type 450 N.
Resistance to impact: Normal.
Resistance to bending: Pliable.
External influences: IP44
Resistance to flame propagation: Flame propagation

First issued on 2013-02-21
Modified on 2018-01-11
Validity date 2023-02-21

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Product certification body accredited by ENAC, number 01/C-PR275